

Product fiche

Ventilation unit: LG 740 F

Specific energy consumption (SEC)	manual control		clock control		central demand control	local demand control
cold climate	-71,6	-72,8	-75,2	-79,5	[kWh/(m ² ·a)]	
average climate	-36,1	-37	-38,7	-41,9	[kWh/(m ² ·a)]	
warm climate	-13,1	-13,8	-15,2	-17,7	[kWh/(m ² ·a)]	

Specific energy consumption class	A	A	A	A
-----------------------------------	---	---	---	---

Type

"residential ventilation system", "bidirectional ventilation system"

Motor and drive

variable speed	x-value	2 [-]
----------------	---------	-------

Type of heat recovery system

recuperative (with moisture recovery)

Thermal efficiency of heat recovery	η_t	80,5% [-]
-------------------------------------	----------	-----------

Maximum flow rate	q_{Vd}	750 [m ³ /h]
-------------------	----------	-------------------------

Electric power input of the fan drive, including any motor control equipment, at maximum flow rate	P_E	254,3 [W]
--	-------	-----------

Sound power level	L_{WA}	46 [dB(A)]
-------------------	----------	------------

Reference flow rate	q_{Vn}	525 [m ³ /h]
---------------------	----------	-------------------------

Reference pressure difference	p_{tU}	50 [Pa]
-------------------------------	----------	---------

Specific power input	SPI	0,2 [W/(m ³ /h)]
----------------------	-----	-----------------------------

Ventilation control (CTRL)

local demand control	1	0,95	0,85	0,65	[-]
----------------------	---	------	------	------	-----

Maximum air leakage rate referred to reference flow rate

internal	q_{vi} / q_{Vn}	0,8% [-]
external	q_{ve} / q_{Vn}	1,5% [-]

Filter change

The filters are to be replaced as soon as:

- the warning light appears on the operator control unit "MINI"
- the command to replace the filters appears on the display of the operator control unit "TOUCH" (marked red in the pictures alongside)



Operator control unit "MINI"

Operator control unit "TOUCH"

CAUTION:

If the filters are not changed regularly, the system can not work efficiently and the power consumption increases.

Waste disposal

Units that are no longer in working order have to be dismantled and properly disposed of by a specialized company via suitable collection centres and in compliance with the waste electrical and electronic equipment ordinance (WEEE), which provides for ratification of community law, directive 202/95/EC (RoHS) and the directive 2002/96/EC (the WEEE directive).

Annual electricity consumption (AEC)	1	2	3	4	electricity
--------------------------------------	---	---	---	---	-------------

Annual heating saved (AHS)

cold climate	83,7	84,3	85,5	88,0	[kWh primary energy/a]
average climate	42,8	43,1	43,7	45,0	[kWh primary energy/a]
warm climate	19,4	19,5	19,8	20,3	[kWh primary energy/a]

Information based on the current state of knowledge of EU Regulations 1253/2014 and 1254/2014

Download from: www.pichlerluft.at

Responsible for the content: J. Pichler Gesellschaft m.b.H.

Photos: Archiv J. Pichler Gesellschaft m.b.H. | Text: J. Pichler Gesellschaft m.b.H.

All rights reserved | All photos are symbolic photos | Subject to change without notice | Version: 10/2024



Systematic ventilation.

J. PICHLER
Gesellschaft m.b.H.

office@pichlerluft.at
www.pichlerluft.at

ÖSTERREICH
9021 KLAGENFURT
AM WÖRTHERSEE
Karlweg 5
T +43 (0)463 32769
F +43 (0)463 37548

ÖSTERREICH
1100 WIEN
Doerenkampgasse 5
T +43 (0)1 6880988
F +43 (0)1 6880988-13

Sales offices in
Slovenia and Serbia.
Sales partners in
Europe.